



TYPE APPROVAL CERTIFICATE

Certificate no.:
TAP00002M1
Revision No:
1

This is to certify:

that the **Flexible Hoses for CO2 Systems**

with type designation(s)
POSEIDON 1SN

issued to

Poseidon Marine Supplies Ltd.
Piraeus, Greece

is found to comply with

DNV rules for classification – Ships Pt.4 Ch.6 Piping systems

DNV class programme DNV-CP-0183 – Type approval – Flexible non-metallic hoses

Application:

Product(s) approved by this certificate is/are accepted for installation on vessels classed by DNV.

Temperature range: -40°C to +100°C

Max. working press.: See page 2.

Sizes: 3/16", 1/4" and 1/2"

Issued at **Høvik** on **2025-07-08**

This Certificate is valid until **2029-01-09**.

for **DNV**

DNV local unit: **Piraeus**

Approval Engineer: **Tobias Berntsen**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to USD 300 000.

Product description

One type of non-metallic flexible hose assembly constructed according to EN 853 1SN, comprised of the following materials:

Tube	:	Black, oil resistant synthetic rubber
Reinforcement	:	Single wire braid of high tensile steel
Cover	:	Black, abrasion resistant neoprene blend, MSHA
Coupling and ferrule	:	Carbon steel 11SMnPb30

Hose assembly location:

Poseidon Marine Suppliers
 6-8 Almyridos Street
 Piraeus, Greece

Application/Limitation

This certificate is valid for the specific assembly of hose and coupling type as specified, assembled, and delivered by the holder (named as manufacturer) of this certificate.

Size	Maximum working pressure	End fittings designation	
		Ferrule	Insert
3/16"	250 bar	FER03	FIT04
1/4"	225 bar	FER02	FIT03, 35.45
1/2"	160 bar	FER01	FIT01, FIT02, 35.45

Hose assemblies covered by this certificate are approved to be used as flexible connections between cylinders and manifolds or cylinders to cylinders in CO2 fire extinguishing systems.

Flexible hoses are only to be used in short lengths where it is necessary due to vibrations or flexible mounting of the machinery and must only be fitted in places where they are always accessible.

The cover on hoses for gaseous systems shall be pin pricked.

Hose assemblies covered by this type approval certificate shall not be installed in systems subject to pressure below atmospheric.

Hose assemblies covered by this type approval certificate shall not be used in systems subject to pressure pulsation.

The outer end of the pipe coupling (performing the connection to the fixed piping) is not covered by this certificate and shall follow the below requirements:

- Flanged ends shall be according to a recognized standard
- Slip-on threaded joints having pipe threads where pressure-tight joints are made on the threads with parallel or tapered threads, shall comply with requirements of a recognized standard. Limitations stated in DNV-RU-SHIP Pt.4 Ch.5 Sec.9 [5.2.6] to be followed.
- If these outer ends are going to be part of a mechanical joints as covered by DNV-RU-SHIP Pt.4 Ch.6 Sec.9 [Table 10], then they shall be separately type approved.

Production testing

All hose assemblies delivered under the DNV type approval scheme shall be subjected to a pressure test at 1.5 times the maximum working pressure and shall be delivered with the pressure test report with reference to this type approval certificate.

Type Approval documentation

Tests carried out

Dimensional check, change in length check, burst pressure test, proof pressure test, cover adhesion test, endurance test, cold flexibility test, ozone resistance test, and fire resistance test.

Marking of product

For traceability to this type approval, the products are at least to be marked with:

- Hose manufacturer's name or trademark;
- Date of manufacture (month/year);
- Designation type reference;
- Nominal diameter;
- Pressure rating;
- Temperature rating.



Job ID: **262.1-038005-2**
Certificate no.: **TAP00002M1**
Revision No: **1**

Periodical assessment

This certificate is only valid if required periodical assessments are carried out with satisfactory results.

For retention of the type approval, a DNV surveyor shall perform periodical assessment after two years (+/- 90 days) and after 3.5 years (+/- 90 days) to verify that the conditions for the approval are complied with. Reference is made to DNV-CP-0338.

To check the validity of this certificate, please look it up in <https://approvalfinder.dnv.com>.

Manufactured by:

Hose assembly location:
Poseidon Marine Suppliers
6-8 Almyridos Street
Piraeus, Greece